

## TRADITIONAL SERIES

P47

P52

P59

**Keep This Manual  
With Air Conditioner**

Find additional information on this model at [kooltronic.com](http://kooltronic.com), or use the Technical Documents QR code below.


Technical Documents  
P47



Technical Documents  
P52



Technical Documents  
P59



# AIR CONDITIONER OPERATOR'S MANUAL

### CAUTION

BEFORE INSTALLING AND USING THIS AIR CONDITIONER, IT IS IMPORTANT THAT THIS MANUAL BE READ AND UNDERSTOOD THOROUGHLY



**KOOLTRONIC, INC.**  
30 Pennington-Hopewell Road  
Pennington, NJ 08534  
609•466-3400  
FAX: 609•466-1114  
[www.kooltronic.com](http://www.kooltronic.com)

# **TABLE OF CONTENTS**

|       |                                      | Page    |
|-------|--------------------------------------|---------|
| I.    | Introduction                         | 2       |
| II.   | Incoming Inspection                  | 3       |
| III.  | Product Handling                     | 3       |
| IV.   | Product Identification and Nameplate | 4       |
| V.    | Principles of Operation              | 5 - 6   |
| VI.   | Pre-Installation Testing             | 6       |
| VII.  | Specific Model Data                  | 7 - 10  |
|       | Mounting                             |         |
|       | Drawings and Dimensions              |         |
|       | Technical Data                       |         |
|       | Major Component Replacements         |         |
| VIII. | Maintenance                          | 11 - 12 |
| IX.   | Trouble Shooting                     | 13      |
| X.    | Warranty                             | 14      |

**NOTE:** Wiring Schematics are available on the specific model page of the Kooltronic website.

## ***I. Introduction***

Kooltronic Air Conditioners are designed to provide a cool, dehumidified environment for your electronic components. There are models to fit virtually all sizes and shapes of electronic enclosures, in capacities ranging from 1,000 to 30,000 BTU/H. Our "closed-loop" design also ensures that your components will not be exposed to hot, dirty operating conditions.

This Manual provides you with the necessary general information for properly installing and operating standard Kooltronic Air Conditioners. Technical data and mounting instructions are presented on pages 7 through 9.

## ***II. Incoming Inspection***

Kooltronic Air Conditioners are designed, built and packaged to withstand the shock and vibration normally associated with shipment by common carriers. Occasionally improper handling during shipping causes damage. Such handling could include unbanding of palletized shipments, failing to respect "**This Side Up**" arrows, rough handling, falling off conveyors, excessive vibration, crushing, etc. Therefore, a thorough inspection should be done upon receipt of all shipments. Any carton tears, dents, scratches, loose articles or evidence of oil are signs of damage and should be noted on the Freight Bill. Cartons should be opened promptly and the units inspected for CONCEALED DAMAGE. Kooltronic Air Conditioners must be delivered in the proper mounting position to assure that damage to the compressor has not occurred during shipping. Any Kooltronic Air Conditioner that is delivered removed from the banded pallet, lying down or double stacked should be refused.

An immediate claim **MUST** be filed with the freight carrier and an inspection requested. Retain all packing materials. Kooltronic cannot assume responsibility for Consignee's failure to file a timely freight claim.

## ***III. Product Handling:***

- 1) Do not attempt to operate your Kooltronic Air Conditioner until you read and thoroughly understand this Manual. See section **VI PRE-INSTALLATION TESTING**.
- 2) Before operating the Kooltronic Air Conditioner be certain that it is placed in its correct mounting position. **This Air Conditioner is designed to operate in a vertical position only.** This placement must be done a minimum of 5 minutes prior to operating in order to allow the compressor oil to drain to the compressor sump area.

### ***CAUTION***

**Kooltronic Air Conditioners must be operated in their proper mounting position. If attempts are made to operate a unit that is not in its designed mounting position, permanent compressor damage will occur. This action will void the warranty. To avoid compressor damage do not tip the unit more than 45° from its proper mounting position.**




- 3) Before operating this unit, all electrical wiring must be checked to assure the proper connection to the correct power source. Minimum circuit ampacity should be at least 125% of the amperage found on the nameplate for the corresponding voltage. Do not exceed the maximum fuse size found on the nameplate.
- 4) We do not recommend that Air Conditioners be shipped to their final destination attached to an enclosure. In the event that the Air Conditioner needs to be shipped attached to an enclosure it is strongly recommended that proper support be provided for the Air Conditioner. Excessive vibration can occur if Air Conditioners are not properly supported when shipped on enclosures, increasing the potential for internal damage and voiding the warranty.
- 5) **PROCEDURE FOR PROPER PACKING AND SHIPMENT OF KOOLTRONIC AIR CONDITIONERS:**
  - Keep Air Conditioner in proper upright position indicated by arrow markers.
  - Pack Air Conditioner in an appropriate carton (preferably original carton if possible), with adequate internal protective packaging, making sure carton is marked and is kept in correct upright position.
  - For local, controlled transportation, strap carton to a secure part of truck to prevent falling or sliding, minimize vibration, etc.
  - For common carrier shipment, band unit(s) securely to a pallet. Unpalletted shipment risks severe damage which voids the warranty.

## IV. Product Identification and Nameplate

Each Kooltronic Air Conditioner includes an identification nameplate. This nameplate provides:

- ① Model Number
- ② Serial Number
- ③ Electrical power characteristics
- ④ Maximum and minimum ambient operating temperatures
- ⑤ Cooling capacity
- ⑥ Type and amount of refrigerant required for recharging
- ⑦ Design Pressure
- ⑧ Maximum Fuse Size
- ⑨ Final Assembly Number
- ⑩ Manufacturing Order Number
- ⑪ Filter Part Number
- ⑫ Underwriters Laboratories Inc. Listed or Recognized Marks and NEMA ratings

We recommend you copy this information from your unit.

|  |       |                 |                |   |            |
|--|-------|-----------------|----------------|---|------------|
|   |       | Air Conditioner |                |   |            |
|  |       |                 |                |   |            |
| ①  |       |                 |                | ②   |            |
| VOLTS  | FREQ. | PH.             | COOLING F.L.A. | AMBIENT TEMP. MIN. °F   | MAX. °F    |
| ③  | ③     | ③               | ③              | ④   | ④          |
| COOLING BTU  |       |                 | REFRIGERANT    | Oz.   |            |
| ⑤  |       |                 |                | ⑥   |            |
| DESIGN PRESSURE P.S.I.G.   |       |                 | MAX. FUSE SIZE |   | FILTER P/N |
| LOW  | HIGH  |                 |                |   | ⑪          |
| ⑦  | ⑦     |                 | ⑧              |   |            |
| FINAL ASSY. NO.  |       |                 | MFG. ORDER NO. |   |            |
| ⑨  |       |                 | ⑩              |   |            |
|  |       |                 |                |  |            |
|  |       |                 |                | ⑫   |            |
| <b>SPECIAL PURPOSE AIR CONDITIONER</b><br>NEMA/EEMAC/UL50 BY UNDERWRITERS LABORATORIES, INC.<br>TYPE 12 INTERFACE TO THE ELECTRICAL ENCLOSURE ONLY   |       |                 |                |   |            |
| <b>NEMA/EEMAC/UL50 BY UNDERWRITERS LABORATORIES, INC.</b><br>TYPE 1 SPECIAL PURPOSE AIR CONDITIONER EQUIPMENT<br>COMPARTMENT ONLY<br>OUTDOOR USE<br>SERVICE AIR FILTER REGULARLY<br>ALLOW 5 MIN. BEFORE RESTARTING AFTER SHUTDOWN<br>UNAUTHORIZED SERVICE OR MODIFICATION<br>VIOLATES WARRANTY<br>ALL MOTORS ARE THERMALLY PROTECTED |       |                 |                |   |            |
| <b>MANUFACTURED BY:</b><br>KOOLTRONIC, INC. PENNINGTON, NJ   |       |                 |                |   |            |
|  |       |                 |                |   |            |


①②⑨⑩ When ordering parts, specify the Model Number, Serial Number, Final Assy. Number & MFG. Order Number.

③ Before operating, be sure that the power source matches these requirements.

④ Make sure that these parameters are met. Failure to do so may result in permanent damage to the unit.

⑥ Use of incorrect type or amount of refrigerant will adversely affect performance and may damage the unit.

## V. Principles of Operation



Kooltronic Air Conditioners are required when the equipment operating temperature must be kept near or lower than the ambient room temperature, and/or the cabinet must be sealed from dust, fumes, oil, corrosives and other contaminants. This Air Conditioner utilizes a “Closed-Loop Cooling System” to ensure optimum performance of the installed components.

Closed-Loop cooling seals the electronics enclosure from hostile elements in the environment. Two separate circulation systems are employed. The internal system cools and dehumidifies the air inside the cabinet, totally isolating the sensitive electronics and other components from the environment. The external system uses circulating ambient air or water to discharge the heat removed from the electronics. The heat is dissipated from the enclosure by means of the vapor compression refrigeration cycle. This takes place in a hermetically-sealed refrigeration system, utilizing either an air-cooled or water-cooled condenser heat exchanger. The warm air inside the enclosure is drawn through the evaporator coil where it is cooled, dehumidified and returned.

Any enclosure moisture accumulated on the evaporator coil is collected in the condensate tray and released to the ambient air through the drain tube or the condensate evaporator.

The heat removed through the evaporator coil is transferred by the compressed refrigerant to the condenser coil. Ambient air or water is then passed through the condenser coil, where it absorbs the heat and is then discharged to the environment.

The cool air discharge temperature is regulated by the capacity control (hot gas bypass) valve. The unit is equipped with a Low Temperature Thermostat to prevent over-cooling. In applications having frequent voluntary heat load fluctuations, an optional Compressor Short Cycle Protector is recommended.

## ***VI. Pre-Installation Testing***

Before mounting the air conditioner to the enclosure, test for proper operation. This will verify the shipping integrity of the system. Please follow the steps below prior to installation.

### ***CAUTION***

**The Air Conditioner must be standing in its proper mounting position for a minimum of five (5) minutes prior to testing. Failure to follow this procedure will cause permanent damage to the compressor.**

1. Allow the unit to sit in a upright position at a room temperature of 65°F minimum, allowing the system to warm-up particularly in winter months.
  2. Refer to the identification label for proper electrical voltage and current requirements. Then connect the power cord to a properly grounded and fused electrical supply. Leave the electrical power off.
  3. Note the factory thermostat setting which is typically 75 to 80°F.
  4. Adjust thermostat to its maximum setting.
  5. If your unit is equipped with an on-off switch, move it to the on position.
  6. Turn electrical power on.
  7. Verify that the evaporator blower or fan is running.
  8. Adjust the thermostat to its minimum setting. The compressor should start. On units equipped with a short cycle protector, the compressor will have a delayed start of 6 minutes from the time power is applied to the unit.
  9. Verify that the condenser blower or fan is running. Note, on units equipped with a low ambient kit, the start of the condenser fan or blower will be delayed until the system pressures rise.
  10. Operate the air conditioner for approximately ten (10) minutes. During this period no unusual noise or vibration should be evident. Both the evaporator and condenser fans or blowers should be delivering air through their respective discharge ports. The cool air should be discharged should be less than 70°F when the room temperature is between 70 and 80°F.
  11. On units equipped with heaters, adjust both the cooling and heating thermostats to their maximum settings. Verify that the compressor and condenser fan or blower has stopped. Verify elevated discharge air temperature from the evaporator air discharge.
  12. If your unit is equipped with an on-off switch, leave it in the on position. Return the cooling thermostat to its original setting. If unit is equipped with a heater, return the heating thermostat to its original position.
  13. Turn off the electrical power source, and disconnect the air conditioner from the power source.
  14. If any cover plug is removed to adjust the unit, make certain to put back in place to maintain the integrity of the closed-loop airflow system.
- NOTE:** Before shipment all Kooltronic, Inc. Air Conditioners are subjected to a performance test.

## ***VII. Specific Model Data***

### ***Mounting***


Kooltronic Air Conditioners have been engineered to be installed easily. To avoid damaging your Air Conditioner, please read the following information before installation.

- Panel-Mounted Air Conditioners are equipped with two vertical mounting rails. These rails can be mounted to any available vertical surface on the enclosure.
- Refer to page 8 for the location of all mounting holes and cutouts.
- Make sure the cutouts don't interfere with components inside your cabinet.
- Proper alignment of all air inlets and outlets is essential for optimum performance of the Air Conditioner.
- All externally-mounted Air Conditioners are fully gasketed to ensure proper sealing. This seal is necessary to maintain the integrity of the closed loop system.
- Use all existing mounting holes to insure stability and a tight seal.
- High strength mounting screws are recommended.
- Attach the brass drain pan fitting and drain hose supplied to the drain exit on the bottom or lower side panel of the Air Conditioner. The optional field installed Condensate Evaporator is mounted underneath the Air Conditioner and the drain hose is connected to the top fitting of the Condensate Evaporator. The drain hoses, fittings and Condensate Evaporator must be removed before dismantling the Air Conditioner, as they will not support the weight of the Air Conditioner unit.
- The external drain hose must not be elevated above the exit port. Improper mounting will impede the flow of condensate and may cause internal malfunctions.

### ***CAUTION***

**If the Air Conditioner is mounted to the cabinet door you must be sure that the door hinges will support the additional weight of the Air Conditioner. Also be certain that when the door is opened fully, the cabinet does not become unbalanced. The actual weight of the unit can be found on page 9.**

# Drawings and Dimensions



## ***DIMENSIONS*** (inches)

| <b>Model</b> | <b>A</b>                       | <b>B</b>                      | <b>C</b> | <b>D</b>                       |
|--------------|--------------------------------|-------------------------------|----------|--------------------------------|
| P47 Series   | 47 <sup>1</sup> / <sub>4</sub> | 2 <sup>5</sup> / <sub>8</sub> | 14       | 39                             |
| P52 Series   | 52 <sup>1</sup> / <sub>2</sub> | 1 <sup>3</sup> / <sub>4</sub> | 16       | 44 <sup>1</sup> / <sub>4</sub> |
| P59 Series   | 59 <sup>1</sup> / <sub>2</sub> | 1 <sup>3</sup> / <sub>4</sub> | 18       | 51 <sup>1</sup> / <sub>4</sub> |



## Technical Data

| Series<br>Height<br>47 52 59 | Model         | **<br>BTU/H<br>Rating | Ambient<br>Temp. °F<br>Max./Min. | ◇<br>Volts | ◇<br>Hz | **<br>Running<br>Amps | Approximate<br>Weight (lbs.) |     |     |
|------------------------------|---------------|-----------------------|----------------------------------|------------|---------|-----------------------|------------------------------|-----|-----|
|                              |               |                       |                                  |            |         |                       | P47                          | P52 | P59 |
| • • •                        | KA4C4P __R    | 4000                  | 131/50                           | 115/100    | 60/50   | 19.0/17.0             | 145                          | 150 | 155 |
| • • •                        | KA4C4P __R56  | 4000                  | 131/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C4P __L   | 4000                  | 131/50                           | 230/200    | 60/50   | 9.0                   | 145                          | 150 | 155 |
| • • •                        | K2A4C4P __L5  | 4000                  | 131/50                           | 230        | 50      | 7.6                   | 145                          | 150 | 155 |
| • • •                        | KA4C5P __R    | 5000                  | 131/50                           | 115/100    | 60/50   | 19.0/17.0             | 145                          | 150 | 155 |
| • • •                        | KA4C5P __R56  | 5000                  | 131/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C5P __L   | 5000                  | 131/50                           | 230/200    | 60/50   | 9.0                   | 145                          | 150 | 155 |
| • • •                        | K2A4C5P __L5  | 5000                  | 131/50                           | 230        | 50      | 7.6                   | 145                          | 150 | 155 |
| • • •                        | KA4C6P __R    | 6000                  | 131/50                           | 115/100    | 60/50   | 19.0/17.0             | 145                          | 150 | 155 |
| • • •                        | KA4C6P __R56  | 6000                  | 131/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C6P __L   | 6000                  | 131/50                           | 230/200    | 60/50   | 9.0                   | 145                          | 150 | 155 |
| • • •                        | K2A4C6P __L5  | 6000                  | 131/50                           | 230        | 50      | 7.6                   | 145                          | 150 | 155 |
| • • •                        | KA4C7P __R    | 7000                  | 131/50                           | 115/100    | 60/50   | 19.0/17.0             | 145                          | 150 | 155 |
| • • •                        | KA4C7P __R56  | 7000                  | 131/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C7P __L   | 7000                  | 131/50                           | 230/200    | 60/50   | 9.0                   | 145                          | 150 | 155 |
| • • •                        | K2A4C7P __L5  | 7000                  | 131/50                           | 230        | 50      | 7.6                   | 145                          | 150 | 155 |
| • • •                        | KA3C8P __R    | 8000                  | 115/50                           | 115/100    | 60/50   | 19.0                  | 145                          | 150 | 155 |
| • • •                        | KA3C8P __R56  | 8000                  | 115/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C8P __L   | 8000                  | 125/50                           | 230/200    | 60/50   | 13.0                  | 145                          | 150 | 155 |
| • • •                        | K2A4C8P __L5  | 8000                  | 115/50                           | 230        | 50      | 12.5                  | 145                          | 150 | 155 |
| • • •                        | KA3C9P __R    | 9000                  | 115/50                           | 115/100    | 60/50   | 19.0                  | 145                          | 150 | 155 |
| • • •                        | KA3C9P __R56  | 9000                  | 115/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C9P __L   | 9000                  | 125/50                           | 230/200    | 60/50   | 13.0                  | 145                          | 150 | 155 |
| • • •                        | K2A4C9P __L5  | 9000                  | 115/50                           | 230        | 50      | 12.5                  | 145                          | 150 | 155 |
| • • •                        | KA3C10P __R   | 10000                 | 115/50                           | 115/100    | 60/50   | 19.0                  | 145                          | 150 | 155 |
| • • •                        | KA3C10P __R56 | 10000                 | 115/50                           | 115        | 50/60*  | 17.0/19.0             | 145                          | 150 | 155 |
| • • •                        | K2A4C10P __L  | 10000                 | 125/50                           | 230/200    | 60/50   | 13.0                  | 145                          | 150 | 155 |
| • • •                        | K2A4C10P __L5 | 10000                 | 115/50                           | 230        | 50      | 12.5                  | 145                          | 150 | 155 |
| • • •                        | KA3C12P __R   | 12000                 | 115/50                           | 115/100    | 60/50   | 19.0                  | 145                          | 150 | 155 |
| • • •                        | K2A4C12P __L  | 12000                 | 125/50                           | 230/200    | 60/50   | 13.0                  | 145                          | 150 | 155 |
| • • •                        | K2A4C12P __L5 | 12000                 | 115/50                           | 230        | 50      | 12.5                  | 145                          | 150 | 155 |

\* Switchable. Switch is internally-mounted for security.

\*\* Rating shown is for operation at maximum ambient temperature.

◇ 115V, 60 Hz and 230V, 60 Hz models also perform at full capacity when operated at 100V, 50 Hz or 200V, 50 Hz respectively. No transformer is required.

## Major Component Replacements

| <b>4,000 to 7,000 BTU/H</b>       |                    |                    |                    |                    |
|-----------------------------------|--------------------|--------------------|--------------------|--------------------|
|                                   | <b>KA4C_P47R</b>   | <b>KA4C_P47R56</b> | <b>K2A4C_P47L</b>  | <b>K2A4C_P47L5</b> |
|                                   | <b>KA4C_P52R</b>   | <b>KA4C_P52R56</b> | <b>K2A4C_P52L</b>  | <b>K2A4C_P52L5</b> |
|                                   | <b>KA4C_P59R</b>   | <b>KA4C_P59R56</b> | <b>K2A4C_P59L</b>  | <b>K2A4C_P59L5</b> |
| <b>Part</b>                       | <b>Part Number</b> | <b>Part Number</b> | <b>Part Number</b> | <b>Part Number</b> |
| Compressor                        | 0665-103           | 0665-103           | 0665-106           | 0665-111           |
| Compressor Capacitor              | N/A                | N/A                | N/A                | N/A                |
| Condenser Blower Motor            | 0261-287           | 0261-287           | 0261-288           | 0261-288           |
| Condenser Blower Motor Capacitor  | 0452-03            | 0452-03            | 0452-03            | 0452-03            |
| Condenser Blower Assembly         | 8060-00-11         | 8060-00-11         | 6076-00-23         | 6076-00-23         |
| Evaporator Blower Motor           | 0261-08            | 0261-08            | 0261-54            | 0261-54            |
| Evaporator Blower Motor Capacitor | 0452-03            | 0452-03            | 0452-03            | 0452-03            |
| Evaporator Blower Assembly        | 6015-00-129        | 6015-00-129        | 6015-00-130        | 6015-00-130        |
| Filter                            | 12251F             | 12251F             | 12251F             | 12251F             |

| <b>8,000 to 12,000 BTU/H</b>      |                    |                    |                    |                    |
|-----------------------------------|--------------------|--------------------|--------------------|--------------------|
|                                   | <b>KA3C_P47R</b>   | <b>KA3C_P47R56</b> | <b>K2A3C_P47L</b>  | <b>K2A3C_P47L5</b> |
|                                   | <b>KA3C_P52R</b>   | <b>KA3C_P52R56</b> | <b>K2A3C_P52L</b>  | <b>K2A3C_P52L5</b> |
|                                   | <b>KA3C_P59R</b>   | <b>KA3C_P59R56</b> | <b>K2A3C_P59L</b>  | <b>K2A3C_P59L5</b> |
| <b>Part</b>                       | <b>Part Number</b> | <b>Part Number</b> | <b>Part Number</b> | <b>Part Number</b> |
| Compressor                        | 0665-42            | 0665-42            | 0665-113           | 0665-114           |
| Compressor Capacitor              | 0452-32            | 0452-32            | 0452-12            | 0452-12            |
| Condenser Blower Motor            | 0261-287           | 0261-287           | 0261-288           | 0261-288           |
| Condenser Blower Motor Capacitor  | 0452-03            | 0452-03            | 0452-03            | 0452-03            |
| Condenser Blower Assembly         | 8060-00-11         | 8060-00-11         | 6076-00-23         | 6015-00-130        |
| Evaporator Blower Motor           | 0261-08            | 0261-08            | 0261-150           | 0261-54            |
| Evaporator Blower Motor Capacitor | 0452-03            | 0452-03            | 0452-03            | 0452-03            |
| Evaporator Blower Assembly        | 6015-00-129        | 6015-00-129        | 6015-00-130        | 6015-00-130        |
| Filter                            | 12251F             | 12251F             | 12251F             | 12251F             |

NOTE: Part Numbers shown are for 60Hz/1Ø. For 50Hz consult Kooltronic.

## ***VIII. Maintenance***

Kooltronic Water-Cooled Air Conditioners require no maintenance. Air-Cooled Air Conditioners are designed to require only the routine cleaning of air filters to assure unimpeded air flow through the condenser heat exchanger. It is not possible to recommend specific filter cleaning intervals since the level and the nature of airborne particulate matter differs widely with each installation. It is generally sufficient to remove and wash the reusable aluminum mesh air filters when the outer surfaces of these filters appear covered with a thin layer of dust or lint. Filter recoating adhesive is recommended. Appropriate disposable filters are available from Kooltronic.

If filter service is neglected or delayed, the air conditioner will not perform at its design capacity. The first indication of excessively clogged air filters is usually a gradual increase of temperature within the equipment cabinet. If operation is continued under these conditions, the compressor will be shut off by the thermal overload device. The compressor will restart when its external temperature drops below the protector threshold setting and the compressor will continue to cycle on and off. Continued operation under these conditions will cause damage, shorten compressor life and void the warranty.

### **A. Filter Removal and Service**

Kooltronic Air Conditioners feature an easily removable inlet filter to facilitate necessary cleaning.

### ***CAUTION***

**Do not operate the Air Conditioner for extended periods of time with the filter removed. The condenser coil may become clogged with dust or lint from the air entering the face. A clogged condenser coil is not readily detected and will give the same reaction as a clogged filter. A clean filter is the best protection.**

- 1) Lift the filter, using the attached tab, to clear the lower filter retainer. Pull filter toward you and downward until the top of the filter clears the upper filter retainer.
- 2) After removal, the filters should be flushed under warm running water with the clean side up, driving contaminants out the dirty side of the filter. If the accumulated dirt is oily, washing in a detergent bath is recommended, followed by a warm water rinse as above.
- 3) The filters may be sprayed with **Kooltronic A-16 Filter Recoating Adhesive** to trap fine airborne contaminants, or they may simply be dried and reinstalled as strainer type filters. **Recoating is recommended for best results.**
- 4) Reinstall the filter: (a) keeping the tab at the bottom, slide filter into the upper retainer, (b) press filter against the unit and (c) slide down into lower retainer.

## B. Blowers

The design life of the blowers employed in all Kooltronic Air Conditioners is substantially in excess of 20,000 hours. All Kooltronic condenser and evaporator blowers are equipped with UL/CSA permanently-lubricated precision ball-bearing motors, with automatic-reset thermal overload protectors.

### **CAUTION**

**Before opening the Air Conditioner, disconnect all power.**

If field replacement of a blower motor is necessary, most blower assemblies, including mounting plate, are readily removable. Each of the blower mounting plates is held to the air conditioner cabinet structure by screws and nuts. For installation of the replacement blower, electrical connections may be broken at the terminal block, or power leads may be cut and appropriately spliced together.

## C. Compressor

All Kooltronic compressors are approved by UL and CSA, and require no maintenance. They are hermetically sealed and charged at the factory, and equipped with automatic-reset thermal overload protectors.

If the compressor or the hot gas bypass valve fails, it is strongly recommended that the Air Conditioner be returned to Kooltronic for service.

## D. Refrigerant Loss

Kooltronic Air Conditioners are subjected to a series of tests to detect refrigerant leaks, during and after manufacture. It is possible that shipping or other damage, or microscopic leaks over a long period, may result in the need for replenishment of refrigerant charge. **When it has been verified by a qualified professional that a refrigerant shortage does exist, the leak must be repaired. Then the unit may be evacuated and recharged in the field by qualified service people only.**

### **CAUTION**

**Refer to the data on the unit name plate which specifies the type of refrigerant and the amount of charge in ounces.**

## E. Relocation

If your Kooltronic Air Conditioner has to be moved to another location by truck, the following precautions should be taken:

- De-mount Air Conditioner from equipment, controller or enclosure.
- Conform to the applicable provisions of PROCEDURE FOR PROPER PACKING AND SHIPMENT OF KOOLTRONIC AIR CONDITIONERS in this manual under *Section III. "PRODUCT HANDLING"*.

## IX. Trouble-Shooting

Each Kooltronic Air Conditioner is engineered for performance and built for reliability. They are designed to require no routine maintenance other than the cleaning of ambient air filters. If your air conditioner should require service, we have compiled a trouble-shooting chart to assist your service personnel. If additional assistance is required contact Kooltronic at 609 • 466-3400.

| <b>Problem</b>                   | <b>Cause</b>   | <b>Solution</b>                               |
|----------------------------------|--|---|
| Unit not Cooling                 | No Power   | Check Power Source and Electrical Connections |
|                                  | Loss of Refrigerant                                      | Locate and repair leak                        |
|                                  | Evaporator or Condenser Blower not operating             | Replace Motor, Capacitor or entire Assembly   |
|                                  | Filter clogged   | Clean or replace Filter                       |
|                                  | Clogged Evaporator or Condenser Coil                     | Clean Coil                                    |
|                                  | Low Temperature Control (Thermostat) improperly set      | Lower setting until unit starts               |
|                                  | Low Temperature Control (Thermostat) defective           | Replace Thermostat or Relay when applicable   |
|                                  | Failed Compressor  | Replace Compressor                            |
| Ice on Evaporator Coil           | Insufficient Heat Load or Unit Oversized for Application | Contact Kooltronic                            |
|                                  | Failed Evaporator Blower                                 | Replace Evaporator Blower Motor or Assembly   |
|                                  | Clogged Evaporator Coil                                  | Clean Coil                                    |
| Condensate draining continuously | Enclosure not properly sealed                            | Check and seal all openings                   |
|                                  | Excessive opening of Enclosure                           | Eliminate the frequency of door opening       |
| Excessive vibration              | Defective Motor in Blower                                | Replace Motor                                 |
|                                  | Defective Wheel in Blower                                | Replace Wheel                                 |
|                                  | Compressor Loose   | Tighten Mounting Bolts                        |
| Compressor Inoperative           | Low line Voltage   | Check Nameplate Voltage against supply        |
|                                  | Loss of Compressor Oil                                   | Replace Compressor                            |
|                                  | Loss of Refrigerant                                      | Locate and repair leak                        |
|                                  | Failed Compressor Capacitor                              | Replace Capacitor                             |
|                                  | Thermal Overload   | Contact Kooltronic                            |
|                                  | Power interruptions                                      | Allow Compressor time to reset                |
| Refrigerant or Oil leaks         | Crack or pin hole in tubing or brazed joint              | Replace tubing or rebraze joint               |

## X. Standard Warranty

KOOLTRONIC products are warranted to be free of defects in workmanship, materials and components. The following warranty periods apply from date of shipment:

- Air moving devices/components and hermetic system components: One year
- Non-operating parts, except filters: 5 years

The above warranty applies when the equipment is operated under the following conditions:

- Ambient temperature not in excess of 125°F (52°C) in normal atmosphere or as stated on product nameplate
- Voltage variation no greater than  $\pm 10\%$  from nameplate rating
- Frequency variation no greater than  $\pm 3\text{Hz}$  from nameplate rating
- Maximum cooling load no higher than air conditioner nameplate rating
- Waiting five minutes before restarting air conditioner after intentional or accidental shutoff
- Compliance to all other installation, maintenance and operating instructions, as supplied
- The purchaser assumes the responsibility of grounding the unit and installing it in accordance with local electrical and safety codes, as well as the National Electric Code (NEC) and OSHA

**KOOLTRONIC cannot assume responsibility for mis-application of its products or the erroneous selection of an inappropriate product by a non-authorized KOOLTRONIC representative. Our applications engineers will gladly assist in the selection of the proper product, provided all required details of the application are furnished.**

**THIS WARRANTY CONSTITUTES THE ENTIRE WARRANTY WITH RESPECT TO THE PRODUCT AND IS IN LIEU OF ALL OTHERS, EXPRESSED OR IMPLIED, INCLUDING ANY WARRANTY OF MERCHANTABILITY AND WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE AND IN NO EVENT IS KOOLTRONIC RESPONSIBLE FOR ANY CONSEQUENTIAL DAMAGES OF ANY NATURE WHATSOEVER.**

### **RETURN AUTHORIZATION (RA) PROCEDURE**

- All returns require a Return Authorization number whether the return is for warranty or non-warranty repair, rotation of stock, damage or any other reason. Returns without an RA number will be refused.
- Customer must call the KOOLTRONIC Customer Service Department, Pennington, New Jersey (609 • 466 • 3400) to obtain an RA number.
- The following information is required when an RA is requested:
  - Original customer Purchase Order number and date
  - Date product was received by customer
  - Number of parts to be returned
  - Product description, model and serial number
  - Reason for return
  - Action requested
  - Contact name, telephone, FAX numbers and e-mail address
- Pack unit in a suitable container for shipment, preferably the

KOOLTRONIC assumes no liability beyond the repair or replacement of its own product. This Warranty does not cover:

- Labor or reimbursement of labor for evaluation, removal, installation, repair, or cost of any warranted part, unless authorized in writing by KOOLTRONIC
- Use of equipment for other than its designed purpose or operating conditions
- Operation in harsh, oily, corrosive or other abnormal environmental conditions, without the proper filtration, sealing, protective coatings and/or weather protection
- Damage to hermetic system resulting from continuous operation with dirty or clogged air filters or improper or negligent maintenance
- Use of refrigerant other than designated
- Customer modification or abuse
- Shipping damage or other accident (Claims for shipping damage are the responsibility of the customer. Timely claims must be filed by the customer with the freight carrier)
- Cracked or broken hermetic tubing, brazed joints or other internal damage caused by shipping or mishandling
- Damage caused by shipping units attached to an enclosure
- Any and all conditions resulting from noncompliance with the preceding operating conditions
- Returned freight must be paid by customer
- **This standard warranty does not apply to custom products. Consult your KOOLTRONIC representative for limitations**

original packaging if available. All Air Conditioners must be returned in an upright position properly secured to a pallet. **Improper packaging may void warranty claim.** If an Air Conditioner is received laying down or shipped via UPS or similar small parcel service the warranty will be void.

- Mark carton prominently with KOOLTRONIC's Return Authorization Number.
- Enclose all pertinent documents.
- Freight charges on all products returned to KOOLTRONIC shall be paid by the customer. Unauthorized collect shipments will be refused.
- If a unit is repaired under Warranty, KOOLTRONIC will pay the freight charges both ways within the Continental USA at KOOLTRONIC's negotiated rates. Warranty repaired units will be returned to customer at KOOLTRONIC expense only within the Continental USA.
- All authorized returns are subject to a restocking fee.